VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

| School District: | 06 - Rocky Mountain |
|--|---|
| School Name: | Open Doors Alternate School |
| REQUIREMENT: Regular inspection and maintenance of HVAC systems | Yes/No: Yes Date of last inspection: 2023-08-01 |
| | Date of next inspection: 2023-12-01 |
| | Date and type of most recent maintenance: Regular filter change and ventilation maintenance. Last maintenance completed in August |
| RECOMMENDATION: Increase supply of outside air | Yes/No: No |
| | Detail: 20% outside air |
| RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible | Yes/No: No |
| | Detail (Including filter grade): Have been using Merv 9A for past two years |
| RECOMMENDATION: | Yes/No: |
| Use other air cleaning or treatment technologies | No Detail: |
| | |
| RECOMMENDATION: Manage energy use and air distribution through building automation control systems | Yes/No: Yes |
| | Detail: Use of Direct Digital Control system. (DDC) |
| Other Relevant Information: | |
| District Contact for any Questions: | Name: Al Ure (Director of Operations) |
| | Phone Number: 250-342-9243 Email: al.ure@sd6.bc.ca |
| | Linaii. di.die@3do.bc.ca |